



2395 Speakman Dr.
Mississauga, ON
Canada L5K 1B3

P: 1 905 822 4111
F: 1 905 823 1446
info.toronto.industrials@element.com
element.com

**PERFORMANCE EVALUATION OF
SLIDING DOOR “RST116 – Sliding Door”
For AŞAS ALUMINUM INDUSTRY AND TRADE CO. INC.**

**IN ACCORDANCE WITH:
AAMA/WDMA/CSA 101/I.S.2/A440-11
AND A440S1-17**

Report to: ASAŞ Aluminum Industry and Trade Co. Inc.
No.2 ASAS Business Center, 34810
Kavacik, Beykoz Istanbul
Turkey

Attention: Ali Osman Ruzgar

Telephone: 416-804-1985
Email: kira@proactivefenestration.com

Report No.: 22-06-B0077-1N
9Pages, 1 Appendix

Proposal No.: 22-006-370929 RV1

Date: October 5, 2022

Product Manufacturer:	ASAŞ Aluminum Industry and Trade Co. Inc.
Product Type:	Sliding Door
Product Series/Model:	RST116 – Sliding Door
Primary Product Designator:	Class AW – PG1920 – Size tested 3150 x 2450 mm– Sliding Door Class AW – PG40 – Size tested 124.02 x 96.46 in – SD
Secondary Product Designator:	
Positive Design Pressure:	1920 Pa (40.10 psf)
Negative Design Pressure:	1920 Pa (40.10 psf)
Water Penetration Resistance:	440 Pa (9.19 psf)
Air Infiltration/Exfiltration	Canadian A3 Level
Test Completion Date:	September 14, 2022
Report Number	22-06-B0077-1N