

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load,
Load-bearing capacity of safety devices



Test Report No. 11-002655-PR01 (PB-A01-02-en-01)

Client ASAS Alüminyum San.ve Tic.A.S.
Rüzgarlı Bace, Asas is Merkezi
34810 Kavacık-Beykoz ISTANBUL
Turkey

Product Tilt and turn window
Designation System designation: RWT 55
Performance-relevant product details Material: Aluminium profiles with thermal break
Overall dimensions (WxH) 1,200 mm x 1,200 mm
Special features

Basis
EN 14351-1:2006+A1:2010

Test standard/s:
EN 1026:2000-06
EN 1027:2000-06
EN 12046-1:2003-11
EN 12211:2000-06
EN 14609:2004-06
Correspond/s to the national standard/s (e.g. DIN EN)

Representation



Results

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class 9A

Resistance to wind load
according to EN 12210:1999-11/AC:2002-08



Class C4

Instructions for use

The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. Observe the specifications set out by the applicable product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

The report contains a total of 19 pages.

ift Rosenheim
10. October 2011

Jörn Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
Building Components


Robert Kotacky, Dipl.-Ing. (FH)
Operating Product Officer
Building Components



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Peichl

Theodor-Gietl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/261-0
Fax: +49 (0)8031/261-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3822
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkannte PÜZ-Stelle: BAY 18
Deutscher Akkreditierungs Rat
DAF-PL-0808 99
DAF-ZE-2288 00
TGA-ZM-16-93-00
TGA-ZM-16-93-80
